

NBG-12WL(A) & NBG-12WLSP SWIFT Wireless Pullstations

The NOTIFIER® SWIFT® addressable pull station is a dual-action, manual pull station with a key-lock reset feature that provides one addressable alarm initiating input. The pull station features similar aesthetic design and durable construction characteristics as the wired counterpart to blend seamlessly throughout the environment. The device communicates to the Fire Alarm Control Panel (FACP) through the SWIFT mesh network and gateway, and is powered by 4 batteries offering a 2-year, UL listed battery life.

Installation is fast and straightforward by using a mounting plate that can be surface mounted. Once the mounting plate is firmly attached to the wall, the pull station is snapped into place and locked down with 3 screws.

The mechanical operation is simple and easy to use in an emergency with a PUSH IN/PULL DOWN handle that latches in the down position to clearly indicate the station has been operated while the word “ACTIVATED” appears on top of the handle in bright yellow, further indicating the operation of the station.

The wireless pull station meets the Americans with Disabilities Act Accessibility Guidelines’ (ADAAG) controls and operating mechanisms guidelines (section 4.1.3[13]) and the Americans with Disabilities Act (ADA) requirement for a 5-pound maximum pull force to activate the pull station and conforms to ANSI/UL Standard 38.

The SWIFT wireless system offers intelligent (addressable) devices which provide secure, reliable communication to the FACP across a Class A mesh network. Wireless devices create an opportunity for applications where it is costly (concrete walls/ceilings, buried wires), obtrusive (surface mount conduit), or possibly dangerous (asbestos) to use traditional wired devices. In addition, both wired and wireless devices can be present on the same FACP providing an integrated wired-wireless solution for increased installation potential.

The mesh network within the SWIFT system creates a child-parent relationship between the devices so that each device has two parents providing a second path for communications on every device. If one device can no longer operate for any reason, the rest of the devices can still communicate with each other, directly or through one or more intermediate devices. Once an initial mesh network is formed, mesh restructuring automatically occurs to find the strongest paths possible within the network.

The SWIFT system also engages frequency hopping to prevent system interference whether intentional or accidental.

Features

- Easy, fast, wireless installation
- Participates in a Class A mesh network
- Built-in tri-color LED, which is visible through the handle of the station, flashes in normal operation and latches steady red when in alarm
- Handle latches in down position and the word “ACTIVATED” appears to clearly indicate the station has been operated
- Maintenance personnel can open station for inspection and address setting without causing an alarm condition
- Standard “code wheel” for setting the SLC address
- For use in commercial applications
- Smooth dual-action design
- Meets ADAAG controls and operating mechanisms guidelines (Section 4.1.3[13]); meets ADA requirement for 5lb. maximum activation force.
- Meets UL 38, Standard for Manually Actuated Signaling Boxes



- Highly visible
- Made of durable polycarbonate material
- Attractive shape and textured finish
- Key reset
- Includes Braille text on station handle

Compatible Control Panels

NOTE: Refer to panel documentation for UL/ULC compatibility.

- N16 INSPIRE™ Series (*UL applications*)
- NFS2-3030
- NFS2-640
- NFS-320/C
- NFS-320SYS/C
- NFW-100X (*UL applications*)
- NFW-50X (*UL applications*)

Electrical and Physical Specifications

Maximum Transmit RF Power: 17 dBm

Radio Frequency Range: 902-928 MHz

Temperature Range: 32°F to 120°F (0°C to 49°C)

Humidity: 10% to 93% Non-condensing

Battery Type: 4 Panasonic® CR123A or 4 Duracell® DL123A

Battery Life: 2 year minimum

Battery Replacement: Upon TROUBLE BATTERY LOW display and/or during annual maintenance

Dimensions: 5.6" (142 mm) H x 4.2" (107 mm) W x 2.1" (53 mm) D

Components and Ordering Information

NOTE: Order "A" models for ULC applications.

- **NBG-12WL(A):** Wireless addressable pull station. Requires (4) CR-123A batteries (included).
- **NBG-12WLSP:** Wireless addressable pull station. Spanish text. Requires (4) CR-123A batteries (included).
- **FWSG(A):** FlashScan Wireless SWIFT Gateway - 1 SWIFT Gateway is required for each wireless mesh, and supports up to 49 SWIFT detectors or modules. Connects to the SLC loop of a compatible panel using FlashScan protocol. Power may be supplied by the SLC circuit or via an optional 24VDC input. See *DN-60820* for other components available for use with the SWIFT Gateway.
NOTE: Use of the 24VDC input may be more convenient for service as it allows for powering down a gateway without shutting down an SLC loop.
- **W-BATCART:** Wireless battery cartridge, 10-pack.
- **SMB500-WH:** Optional surface-mount backbox.

Agency Listings and Approvals

The file number(s) below reference the specific listings for the NBG-12WL(A) & NBG-12WLSP. In some cases, certain modules or applications may not be listed by certain approval agencies, or listing may be in process. Consult Notifier for latest listing status.

- **UL Listed:** S692
- **ULC Listed:** S692
- **CSFM:** 7150-0028:05044
- **FCC ID:** AUBWFSPS
- **IC ID:** 573X-WFSPS
- **NYC Fire Dept:** COA #6217, #6218, #6268
- **FM Approved**

Each device complies with part 15 of the FCC rules meaning operation is subject to the following two conditions: 1) The device may not cause harmful interference and 2) The device must accept any interference received including interference that may cause undesired operation.

Standards and Codes

The SWIFT Wireless pull station complies with the following UL Standards and with NFPA 72 Fire Alarm system requirements.

- UL 864
- UL 268
- ULC S528

NOTIFIER

12 Clintonville Road
Northford, CT 06472
203.484.7161
www.notifier.com



This document is not intended to be used for installation purposes.

We try to keep our product information up-to-date and accurate.

We cannot cover all specific applications or anticipate all requirements.

All specifications are subject to change without notice.

Acclimate® Plus, FlashScan®, Honeywell®, NOTIFIER®, ONYX®, System Sensor®, and SWIFT® are registered trademarks of Honeywell International Inc. Microsoft® and Windows® are registered trademarks of Microsoft Corporation. Duracell® is a registered trademark of Duracell U.S. Operations Inc. Panasonic® is a registered trademark of Panasonic Corporation.

©2022 by Honeywell International Inc. All rights reserved. Unauthorized use of this document is strictly prohibited.

Country of Origin: Mexico

