


## CO capsule for multi-stimulus detector tester 805551



### Part-No.: 805553

Replacement CO capsule (Testifire TC3) for the testing of detectors with carbon monoxide sensors (CO). Especially suited for the OTG multisensor fire detector (CO) IQ8Quad with isolator (Part No. 802473). Suitable for the multi-stimulus detector tester Part No. 805551.

### Common technical data

 The OTG multisensor fire detector (CO) IQ8Quad with isolator (Part No. 802473) is generally tested either -with the test gas Part No. 805584/805584.50, suitable for the smoke detector tester Part No. 805582, or -with Part No. 805552, suitable for the multi-stimulus detector tester Part No. 805551. The Part No. 802473 is VdS-approved as a smoke detector, the CO test gas is required for the additional triggering of the electrochemical CO gas cell.

### Features:

- Non-flammable CO activating material
- Generation of small amounts of CO
- Generation of CO during testing only
- No storing of pressurized CO - no dangerous goods
- More productivity than the spray can