

## EMC shield for IQ8Quad, ES Detect detector base



### Part-No.: 805560

In fire alarm systems where a high electromagnetic interference/EMI load (e.g. by fluorescent lamps or electrical control devices) must be expected it is recommended to mount the EMI-Module in the standard detector base (Part No. 805590) of the corresponding automatic fire alarm detectors.

### Common technical data

Air humidity	< 95 %
--------------	--------



The EMI-Module must only be operated in conjunction with standard detector base (without relay board) and only for detectors without integrated alarm devices (Part No. 802382 to 802386, incl. adapted variants).